

Analysis of Changes for the 6th Edition (2017) Florida Codes

Changes to the Florida Building Code, Residential

This *Analysis of Changes for the 6th Edition (2017) of the Florida Codes* is intended to provide a comprehensive comparison of the provisions in the *5th Edition (2014) Florida Building Code, Residential (FBCR)* and the *6th Edition (2017) Florida Building Code, Residential*. The *2012 International Residential Code* was the base code for the *5th Edition (2014) FBCR*. The *2015 International Residential Code* is the base code for the *6th Edition (2017) FBCR*. As a result of changing the base code and Florida-specific amendments, certain provisions and criteria of the code have changed. This *Analysis* will serve a useful tool to facilitate the transition to the new code.

This *Analysis* is arranged so that comparable provisions in the two codes can be easily located. The left two columns contain section numbers and a brief overview of the corresponding requirements from the *5th Edition (2014) FBCR*. The next two columns contain section numbers and a brief overview of the corresponding requirements in the *6th Edition (2017) FBCR*. The far right column contains a brief analysis or comment on the differences between the provisions.

This *Analysis* is not intended to replace or interpret the provisions contained in either the *5th Edition (2014)* or the *6th Edition (2017) FBCR*. This information simply points out the differences. The *Analysis* is not designed to be used without the aid of the representative code books, as all the details pertaining to a specific section may or may not be provided. However, this *Analysis* will provide an easy means for identifying differences in the two codes, as well as enabling the user to locate issue specific provisions in the *6th Edition (2017) FBCR* by means of a numbered section cross reference.

This *Analysis* provides a cross-reference for the majority of the sections that changed in the *6th Edition (2017) FBCR*. In some cases, sections were grouped together due to substantial differences. This grouping enables the extent of the differences to be more readily identified.

Notable changes deemed to be the most significant or to have the greatest impact have been highlighted in **yellow**.

Note: Seismic loading and snow loading provisions in the code are no longer reserved (deleted) in the *6th Edition (2017) FBCR*, even though they do not apply in the State of Florida. While there are changes to some of these sections and provisions, they are not shown here in this *Analysis* because they do not apply to construction in the State of Florida.

Additionally, the prescriptive provisions of the base code (IRC) for low wind regions have been retained in the *6th Edition (2017) FBCR*. However, Section R301.2.1.1 states that these provisions do not apply, which includes Sections R502, R503, R505 R602, R603, R606, R802, and R804. While there are changes to some of these sections and provisions, they are not shown here in this *Analysis* because they do not apply to construction in the State of Florida.

5 th Edition (2014) FBCR		6 th Edition (2017) FBCR		Analysis
Section	Requirement	Section	Requirement	
Chapter 1: Scope and Administration				
R101.2	Scope	R101.2	Scope	<p>Scope revised to increase the maximum height of accessory structures to 3 stories. Previously, the definition of “Accessory Structure” limited these structures to not more than 2 stories. This definition has also been revised.</p> <p>Exception 1 has been revised to limit the applicability to Live/work units that are located in townhouses.</p>
Chapter 2: Definitions				
R202	Definitions: Accessory Structure	R202	Definitions: Accessory Structure	Definition revised to remove technical criteria. Section R101.2 increases the maximum height of accessory structures from 2 stories to 3 stories.
-	-	R202	Definitions: Alternating Tread Device	New definition added for alternating tread device consistent with the definition in the FBCB.
R202	Definitions: Alteration	R202	Definitions: Alteration	Definition revised to building, electrical, gas and plumbing systems to the scope of the definition.
R202	Definitions: Attic	R202	Definitions: Attic	Definition revised to clarify that an attic can be on parts of a building other than the just the top story.
R202	Definitions: Backflow Preventer	R202	Definitions: Backflow Preventer	Definition revised for clarity and consistency with the FBCP.
-	-	R202	Definitions: Building-integrated Photovoltaic Product	New definition applicable to products that incorporate PV modules and functions as a component of the building envelope.
-	-	R202	Definitions: Circulating Hot Water System	New definition.
-	-	R202	Definitions: Collection Pipe	New definition applicable to unpressurized pipe that drains nonpotable water to a storage tank by gravity.
R202	Definitions: Conditioned Space	R202	Definitions: Conditioned Space	Definition revised for clarity and consistency with the FBCEC and FBCM.

R202	Definitions: Contamination	R202	Definitions: Contamination	Definition revised to clarify that contamination of the water supply is a high hazard or health hazard impairment of the quality of potable water.
-	-	R202	Definitions: Continuous Insulation	New definition applicable to the residential provisions of the FBCEC.
-	-	R202	Definitions: Cross-laminated Timber	New definition applicable to prefabricated engineered wood products.
-	-	R202	Definitions: Direct System	New definition applicable to a type of solar heating system.
-	-	R202	Definitions: Drain-back System	New definition applicable to a type of solar heating system.
-	-	R202	Definitions: Engineered Wood Rim Board	New definition applicable to a specific prefabricated engineered wood product.
-	-	R202	Definitions: ERI Reference Design	New definition applicable to the residential provisions of the FBCEC.
-	-	R202	Definitions: Factory-made Air Duct	New definition added.
R202	Definitions: Fiber-cement Siding	R202	Definitions: Fiber-cement (Backerboard, Siding, Soffit, Trim and Underlayment) Products	Definition revised to be consistent with ASTM C 1154 which governs these types of products.
R202	Definitions: Fire Separation Distance	R202	Definitions: Fire Separation Distance	Definition revised to clarify that the fire separation distance measurement for zero lot line developments on apply to jurisdictions that permit zero lot line developments.
-	-	R202	Definitions: Flexible Air Connector	New definition added for a term used in the code.
-	-	R202	Definitions: Gypsum Board	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCB.
-	-	R202	Definitions: Gypsum Panel Product	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCB.
-	-	R202	Definitions: Historic Building	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCB.
-	-	R202	Definitions: Indirect System	New definition applicable to a type of solar heating system.
-	-	R202	Definitions: Insulated Siding	New definition added for a type of

				continuous insulation.
-	-	R202	Definitions: Insulated Vinyl Siding	New definition added for a vinyl cladding product with manufacturer-installed foam plastic insulating material.
R202	Definitions: Masonry Unit	R202	Definitions: Masonry Unit	Definition revised to include architectural cast stone as a masonry unit.
-	-	R202	Definitions: Mechanical Joint	New definition for describing what constitutes a mechanical connection between pipes, fitting, or pipes and fittings.
-	-	R202	Definitions: Metal Roof Panel, or Metal Roof Shingle Manufacturer	New definition describing the party responsible for forming sheet metal raw materials into the metal roof panels and/or shingles.
R202	Definitions: Mezzanine, Loft	R202	Definitions: Mezzanine	Definition revised for consistency with the FBCB and new provisions in Section R325 for mezzanines.
-	-	R202	Definitions: Nailable Substrate	New definition applicable to new provisions added to Chapter 7 for exterior wall coverings.
-	-	R202	Definitions: On-site Nonpotable Water Reuse Systems	New definition applicable to new provisions in Section P2911
-	-	R202	Definitions: Photovoltaic Module	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCB.
-	-	R202	Definitions: Photovoltaic Panel	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCB.
-	-	R202	Definitions: Photovoltaic Panel System	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCB.
R202	Definitions: Photovoltaic Modules/Shingles	R202	Definitions: Photovoltaic Shingles	Definition revised for clarity and consistency with the FBCB.
R202	Definitions: Plumbing Systems	R202	Definitions: Plumbing Systems	Definition revised for consistency with the FBCB.
-	-	R202	Definitions: Polypropylene Side	New definition for a new exterior wall cladding now regulated by Chapter 7.
R202	Definitions: Pollution	R202	Definitions: Pollution	Definition revised to enable a better determination of the type of backflow prevention assembly, backflow prevention device, means or method required.

-	-	R202	Definitions: Reclaimed Water	New definition applicable to new provisions in Section P2913
R202	Definitions: Registered Design Professional	R202	Definitions: Registered Design Professional	Definition revised to clarify that the term includes and design professional so long as they are practicing with the scope of their license.
-	-	R202	Definitions: Roof Replacement	New definition applicable to the reroofing provisions of Chapter 9.
-	-	R202	Definitions: Shingle Fashion	New definition describing the method of applying moisture control layers such as roof underlayment and water-resistive barriers.
-	-	R202	Definitions: Stairway, Spiral	New definition for spiral stairway consistent with the definition in the FBCB.
R202	Definitions: Townhouse	R202	Definitions: Townhouse	Revised to limit townhouses to a maximum of 3 stories to be consistent with Florida Statutes.
-	-	R202	Definitions: Waste Receptor	New definition added for a term used in the code. Definition is consistent with the way the term is defined in the FBCP.
R202	Definitions: Wood/Plastic Composite	R202	Definitions: Plastic Composite	Definition revised for clarity.
Chapter 3: Building Planning				
R301.2.1.1	Wind limitations and wind design required	R301.2.1.1	Wind limitations and wind design required	Revised to clarify that specific prescriptive provisions in the FBCR do not apply to construction in the State of Florida. In previous versions of the FBCR, the prescriptive provisions that did not apply were deleted. In the 6 th Edition (2017) those prescriptive provisions remain in the code, but Section R301.2.1.1 states that they do not apply where V_{ult} equals or exceeds 115 mph (all of Florida). The prescriptive provisions include Sections R502, R503, R505, R602, R603, R606, R802 and R804. New language clarifies that the roof sheathing attachment provisions of Section R803 do apply.
R301.2.1.1.2.1	Sunroom design	R301.2.1.1.1	Sunrooms	Section revised to clarify the applicable loads on elements that qualify as

				components and cladding and those that qualify as part of the main wind-force resisting system.
Table R301.2(2)	Component and Cladding Loads for a Building with a Mean Roof Height of 30 feet Located in Exposure B	Table R301.2(2)	Component and Cladding Loads for a Building with a Mean Roof Height of 30 feet Located in Exposure B (ASD)	Design wind pressures in the table have been adjusted to ASD-level loads. New Note f. clarifies that the pressures have already been multiplied by 0.6 to convert them to ASD-level loads.
R301.2.1.2	Protection of openings	R301.2.1.2	Protection of openings	Exception for using wood structural panels for opening protection in wind-borne debris regions has been revised based on new research. The maximum span has been reduced from 8 feet to 44 inches. New prescriptive attachment methods are provided for wood, masonry, and concrete construction. The prescriptive fastening table has been deleted.
Table R301.2.1.2	Wind-borne Debris Protection Fastening Schedule for Wood Structural Panels	-	-	Table deleted.
R301.2.1.7	Basic wind speed	-	-	Section requiring wind speed lines to be determined by local ordinance using recognized physical landmarks such as major roads, canals, rivers and lake shores has been deleted.
R301.2.4	Floodplain construction	R301.2.4	Floodplain construction	New language clarifies that buildings and structures that are located in more than one flood hazard area have to comply with the provisions associated with the most restrictive flood hazard area.
Table R301.7	Allowable Deflection of Structural Members	Table R301.7	Allowable Deflection of Structural Members	Table revised to clarify the exterior wall deflection limits are due to wind loads. Also revised to clarify that the allowable deflection for ceilings with flexible finishes, which includes gypsum wallboard, is L/240. Note a has been revised for consistency with the tabulation of ASD-level wind pressures in Table R301.2(2).
R302.1	Exterior walls (fire resistant construction)	R302.1	Exterior walls (fire resistant construction)	Exception 7 has been revised to clarify that the zero lot line exception only applies

				where permitted in local regulations.
Table R302.1	Exterior Walls	Table R302.1	Exterior Walls	New Note b permits required the roof-eave fire-resistance rating to be omitted where fireblocking is installed. New Note c permits required the roof-eave fire-resistance rating to be omitted where gable vent openings are not installed.
R302.2.2	Parapets	R302.2.2	Parapets for townhouses	The exception has been revised to require that the Class C rating of the roof covering has to be determined by tests in accordance with ASTM E 108 or UL 790.
R302.6	Dwelling-garage fire separation	R302.6	Dwelling-garage fire separation	New language added requiring that gypsum board required in Table R302.6 is required to be attached in accordance with Table R702.3.5.
R302.10.1	Insulation (flame spread and smoke-developed index)	R302.10.1	Insulation (flame spread and smoke-developed index)	Exception 2 is revised to specifically state cellulose fiber loose-fill insulation
R302.11.1	Fireblocking materials	R302.11.1	Fireblocking materials	Item 8 revised to require cellulose insulation to be tested in accordance with ASTM E 119 or UL 263
R303.1	Habitable rooms	303.1	Habitable rooms	Revised to permit the use of skylights for natural ventilation.
R303.5.1	Intake openings	R303.5.1	Intake openings	Section editorially reformatted for clarity.
R303.7	Stairway illumination	R303.7	Interior stairway illumination	Stairway illumination requirements divided into 2 sections for clarity.
		R303.8	Exterior stairway illumination	
R304.1	Minimum area	R304.1	Minimum area	The requirement that all dwelling units have at least one habitable room with a floor area of not less than 120 square feet has been deleted.
		R304.2	Other rooms	
R305.1	Minimum height (ceilings)	R305.1	Minimum height (ceilings)	Section revised to permit bathrooms and toilet rooms to have a minimum ceiling height of 6 feet 8 inches. New exception permits beams, girders, ducts and other obstructions in basements containing habitable spaces to project within 6 feet 4 inches of the finished floor.
R308.1	Identification (glazing)	R308.1	Identification (glazing)	Florida-specific amendment requiring each pane or glazing to bear the manufacturer's label designating the type and thickness of glass or glazing material has been deleted.

				The provision now only applies to glazing in hazardous locations. Florida-specific amendment requiring laminated glass to be permanently identified has been deleted.
R308.4.2	Glazing adjacent to doors	R308.4.2	Glazing adjacent to doors	Section revised to consider glazing on wall that is perpendicular to plane of the door in a closed position and within 24 inches of the "hinge" side of the door as a hazardous location. Such glazing located on the non-hinge side would not be considered a hazardous location.
R308.4.5	Glazing and wet surfaces	R308.4.5	Glazing and wet surfaces	Exception revised to add shower, sauna, and steam room to the list in the exception to requiring safety glazing in locations within and adjacent to areas with wet surfaces.
R308.4.7	Glazing adjacent to the bottom stair landing	R308.4.7	Glazing adjacent to the bottom stair landing	Horizontal dimension measurement of this section has been revised to only apply to any glazing that is in a wall that is less than 180 degrees from the bottom tread nosing.
-	-	R308.6.9.1	Comparative analysis for glass-glazed unit skylights	New section providing criteria using a comparative analysis for glass-glazed skylights structural wind load design pressures.
R310	Emergency escape and rescue openings	R310	Emergency escape and rescue openings	Section reorganized for clarity and to clarify the doors are also a viable emergency escape and rescue option.
R310.1.4	Operational constraints	R310.1.1	Operational constraints and opening control devices	New language permits the use of window opening control devices on windows serving as required emergency escape and rescue openings.
§	§	R310.2.5	Replacement windows	New section permitting replacement windows to be exempt from the minimum dimensional requirements for emergency escape and rescue openings provided the replacement window meets the minimum criteria specified.
-	-	R310.5	Dwelling additions	New section requiring dwelling additions that contain sleeping rooms or basements to have an emergency escape and rescue opening. Two exceptions are provided.

-	-	R310.6	Alterations or repairs of existing basements	New section stating that an emergency escape and rescue opening is not required for a basement undergoing an alteration or repair unless new sleeping rooms are created.
R311.1	Means or egress	R311.1	Means or egress	Section revised to clarify the required egress is required to open directly into a public way or to a yard or court that opens to a public way.
R311.3.2	Floor elevations for other exterior doors	R311.3.2	Floor elevations for other exterior doors	Exception revised to clarify that the top landing is not required in accordance with the exception.
R311.7.2	Headroom	R311.7.2	Headroom	New exception permitting the headroom for spiral stairs to be in accordance with Section R311.7.10.1.
R311.7.3	Vertical rise	R311.7.3	Vertical rise	The maximum vertical rise of a flight stairs has been increased from 12 feet to 47 inches.
R311.7.5.1	Risers	R311.7.5.1	Risers	Two new exceptions permits the opening between adjacent treads on spiral stairway to not be limited and the riser height of spiral stairways to be in accordance with Section R311.7.10.1. The exception for the opening between adjacent treads not being limited on stairs with a total rise of 30 inches or less has been incorporated into the body of the section.
R311.7.5.2.1	Winder treads	R311.7.5.2.1	Winder treads	New exception permitting the tread depth for spiral stairs to be in accordance with Section R311.7.10.1.
R311.7.10.1	Spiral stairways	R311.7.10.1	Spiral stairways	Section revised to require the walkline radius for spiral stairs to be not greater than 24½ inches. Minimum tread depths for spiral stairs have been reduced to 6-3/4 inches.
-	-	R311.7.11	Alternating tread devices	New section permitting the use of alternating tread devices provided they are not part of the required means of egress.
-	-	R311.7.12	Ships ladders	New section permitting the use of ships ladders provided they are not part of the

				required means of egress.
R311.8.1	Maximum slope (ramps)	R311.8.1	Maximum slope (ramps)	Revised to require only ramps serving the required egress door to have a maximum slope of 1:12. All other ramps are permitted to have a maximum slope of 1:8.
R312.1.1	Where required (guards)	R312.1.1	Where required (guards)	The horizontal location of guards from the open side has been changed from within 36 inches to the open side to within 24 inches of the open side.
R312.1.2	Height	R312.1.2	Height	The requirement that guards extend 36 inches in height above adjacent fixed seating has been deleted.
R312.2.1	Window sills	R312.2.1	Window sills	Section reorganized for clarity. Exceptions are revised to apply to “operable” windows.
R314	Smoke alarms	R314	Smoke alarms	Section reorganized in a more logical order for clarity.
R314.3	Location	R314.4.3	Location	New language requires smoke alarms to be installed not less than 3 feet from the door or opening of a bathroom that contains a bathtub or shower.
-	-	R314.3.1	Installation near cooking appliances	New section limiting the location of smoke alarms with respect to cooking appliances.
R316.3	Surface burning characteristics (foam plastic)	R316.3	Surface burning characteristics (foam plastic)	Revised to require the product to also be tested in the maximum density as well as the maximum thickness.
R316.4	Thermal barrier	R316.4	Thermal barrier	Section revised to permit the use of 23/32-inch wood structural panel as a thermal barrier.
R316.5.3	Attics	R316.5.3	Attics	Section reorganized to clarify that the thermal barrier is not required when foam plastic insulation is tested in accordance with Section R316.6. 1/4 -inch fiber cement panel, soffit or backer board is added as an ignition barrier.
R316.5.4	Crawl spaces	R316.5.4	Crawl spaces	Section reorganized to clarify that the thermal barrier is not required when foam plastic insulation is tested in accordance with Section R316.6.
R316.5.11	Sill plates and headers	R316.5.11	Sill plates and headers	Section revised to allow the use of spray-applied foam in the perimeter of joist spaces

				without a thermal barrier.
R316.5.12	Sheathing	R316.5.12	Sheathing	New language requires foam plastic insulation used as an exterior wall sheathing to comply with the wind resistance requirements of new Section R316.8.
-	-	R316.8	Wind resistance	New section requiring foam plastic insulation used as an exterior wall sheathing to comply with SBCA FS 100 for wind resistance.
R317.1.4	Wood columns	R317.1.4	Wood columns	New exception added for deck posts supported by concrete piers or metal pedestals projecting not less than 1 inch above a concrete floor or 6 inches above exposed earth.
R317.3	Fasteners and connectors in contact with preservative-treated and fire-retardant-treated wood	R317.3	Fasteners and connectors in contact with preservative-treated and fire-retardant-treated wood	Revised to require stainless steel driven fasteners to be in accordance with ASTM F 1667.
R319	Site address	R319	Site address	Section revised to require address numbers to be alphanumeric and not be spelled out.
R322.1	General (flood-resistant construction)	R322.1	General (flood-resistant construction)	Section revised to add Coastal A zone, substantial improvement and restoration of substantial damage to the scope of this section. Requires buildings and structures located in more than one flood hazard area to comply with most restrictive flood hazard area.
R322.1.5	Lowest floor	R322.1.5	Lowest floor	Revised for clarity and to match NFIP regulations.
R322.1.8	Flood-resistant materials	R322.1.8	Flood-resistant materials	Revised to require materials used below the elevations required in Section R322.2 or R322.3 to be in accordance with FEMA TB-2.
R322.2	Flood hazard areas (including A zones)	R322.2	Flood hazard areas (including A zones)	Revised to require Coastal A zones to comply with Section R322.3.
R322.2.1	Elevation requirements (A zones)	R322.2.1	Elevation requirements (A zones)	Section revised to add 1 foot of freeboard to the elevation requirements
R322.2.2	Enclosed area below design flood elevation	R322.2.2	Enclosed area below design flood elevation	Section reorganized to put all of the installation requirements in a separate section, separating installation from the requirements that apply to the openings themselves. Clarifies that the square foot
		R322.2.2.1	Installation of openings.	

				area of enclosures is to be measured from the outside and that the net open area calculation has to take into account if there are louvers, blades, screens and faceplates because their presence affects the flow of water.
-	-	R322.2.4	Tanks	New section specifying anchorage requirements for underground and above-ground tanks
R322.3	Coastal high-hazard areas (including V Zones)	R322.3	Coastal high-hazard areas (including V Zones and Coastal A Zones, where designated)	Revised to add Coastal A Zones to the scope of this section.
R322.3.2	Elevation requirements (V zones and Coastal A zones)	R322.3.2	Elevation requirements (V zones and Coastal A zones)	Section revised to add 1 foot of freeboard to the elevation requirements
R322.3.3	Foundations	R322.3.3	Foundations	New exception for stem wall foundations supporting a floor system in Coastal A zones that meet the requirements of the exception.
R322.3.4	Walls below design flood elevation	R322.3.4	Walls below design flood elevation	New language requires walls intended to break away under flood loads to have flood openings that meet the criteria in Section R322.2.2, Item 2.
-	-	R322.3.5.1	Protection of building envelope	New section requiring exterior doors that comply with the wind load requirements of Section R609 to be installed at the top of stairs that provide access to the building and that are enclosed with walls designed to break away.
-	-	R322.3.7	Tanks	New section specifying anchorage requirements for underground and above-ground tanks
-	-	R324	Solar Energy Systems	New section providing general requirements for solar energy systems including roof-mounted photovoltaic systems, building-integrated photovoltaic systems, and ground-mounted photovoltaic systems.
-	-	R325	Mezzanines	New section providing criteria related to mezzanine size, height, means of egress, and openness based on the mezzanine provisions in the FBCB.

-	-	R326	Swimming Pools, Spas and Hot Tubs	New general section requiring that the design of pools and spas to comply with Chapter 45.
Chapter 4: Foundations				
-	-	R402.2.1	Materials for concrete	New general section referencing Section R608.5.1 for concrete materials.
-	-	R402.4	Masonry	New section requiring masonry to have a minimum specified compressive strength of 1500 psi.
Table R403.1	Minimum Width of Concrete, Precast, or Masonry Footings.	Table R403.1(1)	Minimum Width and Thickness for Concrete Footings for Light-Frame Construction	The prescriptive provisions for minimum size of concrete footings based on gravity loads have been revised by replacing the existing Table R403.1 with three new tables that account for additional roof live load conditions and additional load bearing values of soil.
		Table R403.1(2)	Minimum Width and Thickness for Concrete Footings for Light-Frame Construction with Brick Veneer	
		Table R403.1(3)	Minimum Width and Thickness for Concrete Footings with Cast-In-Place Concrete or Fully Grouted Masonry Wall Construction	
R403.1.6	Foundation anchorage	R403.1.6	Foundation anchorage	Section revised to clarify the foundation anchorage requirements for cold-form steel framing. Requires anchor bolts to be located in the middle third of the width of the plate.
R404.1.1	Design of masonry foundation walls	R404.1.1	Design of masonry foundation walls	The reference to NCMA TR68 A for the design and construction of masonry foundation walls has been deleted.
Table R404.1.1 (1)	Plain Masonry Foundation Walls	Table R404.1.1 (1)	Plain Masonry Foundation Walls	The minimum thickness for wall heights of 8 and 9 feet were revised to be consistent with TMS 402/ACI 530/ASCE 5 section 5.6.3 and Table 5.6.3.1.
R404.4	Retaining walls	R404.4	Retaining walls	Revised to increase the limits for when retaining walls have to be design. The scope now applies to retaining walls that retain in excess of 48 inches of unbalanced fill or retaining walls that exceed 24 inches in height. New language clarifies that this section does not apply to foundation walls supporting buildings.
R405.1	Concrete or masonry foundations	R405.1	Concrete or masonry foundations	New language limiting the use of filter

	(foundation drainage)		(foundation drainage)	membranes on perforated drains where not recommended by the drain manufacturer.
R406.1	Concrete or masonry foundation dampproofing	R406.1	Concrete or masonry foundation dampproofing	Section revised to require foundation walls that retain earth and enclose interior spaces and floors below grade to be dampproofed from the higher of "(a) the top of the footing or (b) 6 inches below the top of the basement floor."
R406.2	Concrete or masonry foundation waterproofing	R406.2	Concrete or masonry foundation waterproofing	Section revised to require in areas with a high water table or other severed soil-water conditions are known to exist, foundation walls that retain earth and enclose interior spaces and floors below grade to be waterproofed from the higher of "(a) the top of the footing or (b) 6 inches below the top of the basement floor."
Chapter 5: Floors				
R501.3	Fire protection of floors	R302.13	Fire protection of floors	New language added permitting specific types of penetrations including ducts, vents, electrical, outlets, and lighting among others.
R502.1	Identification	R502.1.1	Sawn lumber	Section revised to clarify the process by which lumber design values are certified and recognized in the code.
R502.1.6	Structural log members	R502.1.4	Structural log members	Section revised to require structural log members to comply with ICC-400.
-	-	R502.1.6	Cross-laminated timber	New section requiring cross-laminated timber to manufactured and identified as required by ANSI/APA PRG 320.
-	-	R502.1.7	Engineered wood rim board	New section requiring engineered wood rim boards to conform to ANSI/APA PRR 410 or be evaluated in accordance with ASTM D 7672. Structural capacities are required to be in accordance with ANSI/APA PRR 410 or established in accordance with ASTM D 7672. Rim boards conforming to ANSI/APA PRR 410 are required to be marked in accordance with that standard.
R506.2.2	Base (concrete floors on ground)	R506.2.2	Base (concrete floors on ground)	Revised to add crushed concrete as an

				acceptable base material.
R506.2.4	Reinforcement support	R506.2.4	Joints	New section applicable to construction and contraction joints. Requires contraction joints to be in accordance with ACI 332. Contraction joints are not required where the concrete contains fiber reinforcement or where welded wire fabric meeting the specified requirements is provided.
R507	Decks	R507	Exterior decks	The prescriptive provisions for constructing exterior decks have been revised significantly based on new calculations and in order to clarify the provisions. New prescriptive provisions are provided for plastic composite deck boards, stair treads, guards, or handrails.
Chapter 6: Wall Construction				
R602.1	Identification	R602.1.1	Sawn lumber	Section revised to clarify the process by which lumber design values are certified and recognized in the code.
R602.1.3	Structural log members	R602.1.4	Structural log members	Section revised to require structural log members to comply with ICC-400.
-	-	R602.1.6	Cross-laminated timber	New section requiring cross-laminated timber to manufactured and identified as required by ANSI/APA PRG 320.
-	-	R602.1.7	Engineered wood rim board	New section requiring engineered wood rim boards to conform to ANSI/APA PRR 410 or be evaluated in accordance with ASTM D 7672. Structural capacities are required to be in accordance with ANSI/APA PRR 410 or established in accordance with ASTM D 7672. Rim boards conforming to ANSI/APA PRR 410 are required to be marked in accordance with that standard.
-	-	R602.1.9	Particleboard	New section requiring particleboard to conform to ASTM A208.1.
-	-	R602.1.10	Fiberboard	New section requiring fiberboard to conform to ASTM C 208.
R604.3	Installation (wood structural panels)	R604.3	Installation (wood structural panels)	Language recognizing wood structural panels marked Exposure 1 or Exterior as water-repellant sheathing has been deleted

				as wood structural panels are not recognized as a weather-resistive barrier.
R606	General Masonry Construction	R606	General Masonry Construction	The prescriptive high-wind provisions for masonry construction in previous editions of the FBCR have been deleted. The provisions in R606 in the 6 th Edition (2017) are based on empirical design of masonry and do not apply in accordance with Section R301.2.1.1. Masonry construction is required to comply with Section R301.2.1.1.
R607	Unit Masonry			
R608	Multiple Wythe Masonry			
R609	Grouted Masonry			
R611	Exterior Concrete Wall Construction	R608	Exterior Concrete Wall Construction	The prescriptive provisions for exterior concrete wall construction have been updated for consistency with PCA 100-2012, ACI 318-11, and ASCE 7-10.
R611.5.1	Concrete and materials for concrete	R608.5.1	Concrete and materials for concrete	Section revised to permit concrete and concrete materials to comply with PCA 100.
-	-	R608.5.1.1	Cements	New section permitting cements to comply with ASTM C150, ASTM C595, or ASTM C1157.
R612.2.1	Custom doors	R609.2.1	Custom doors	Section revised for clarity. New language requires signed and sealed copies of the rational analysis and calculations to be provided to the building official upon permit application for custom doors.
R612.3	Testing and labeling (exterior windows and doors)	R609.3	Testing and labeling (exterior windows and doors)	Revised to permit the use of ANSI/WMA 100 for testing and labeling exterior side-hinged doors.
R612.3.1	Comparative analysis	R609.3.1	Comparative analysis	WDMA I.S.11 has been added an option for a comparative analysis method.
R612.8.2	Deflection (mullions)	R609.8.2	Deflection (mullions)	Deflection limits have been strengthened by limiting spans up to 13 foot 6 inches to L/175 and spans over 13 foot 6 inches to L/240.
R612.9	Door components	R609.10	Door components	The provisions for substituting door components have been revised to simply require substitution of door components to be in accordance with ANSI/WMA 100.
R612.9.1	Optional exterior door component testing			
R613.5(1)	Minimum Thickness for SIP Wall Supporting SIP or Light-frame Roof Only	R610.5(1)	Minimum Thickness for SIP Wall Supporting SIP or Light-frame Roof Only	The design assumptions in Note a have been revised to clarify they are maximums. Wind speed columns have been updated to

				strength design level.
R613.5(2)	Minimum Thickness for SIP Wall Supporting SIP or Light-frame Story One Roof Only	R610.5(2)	Minimum Thickness for SIP Wall Supporting SIP or Light-frame Story One Roof Only	The design assumptions in Note a have been revised to clarify they are maximums. Wind speed columns have been updated to strength design level.
R613.7	Drilling and notching	R610.7	Drilling and notching	A 2 inch tolerance was added for chase penetrations to ease use in the field. New language permits additional penetrations of SIP panels where justified by analysis.
R614	Combined Concrete, Masonry, or ICF and Wood Exterior Wall Construction	-	-	Section deleted.
Chapter 7: Wall Covering				
R702.3.3	Cold-formed steel framing (gypsum panel products)	R702.3.3	Cold-formed steel framing (gypsum board)	Section revised to require nonload-bearing cold-formed steel to also comply with AISI S220 and load-bearing cold-formed steel to also comply with AISI S200.
Table R702.3.5	Minimum Thickness and Application of Gypsum Board and Gypsum Panel Products	Table R702.3.5	Minimum Thickness and Application of Gypsum Board	Note e, which required the use of 5/8" Type X gypsum board on garage ceilings when there are habitable rooms above has been relocated to a new row directly in the table for clarity.
R702.3.8	Water-resistant gypsum backing board	R702.3.7	Water-resistant gypsum backing board	Section revised to delete the requirement that limits framing spacing for water-resistant gypsum backing board installed on ceilings to not exceed 12 inches on center for 1/2-inch-thick or 16 inches for 5/8-inch-thick gypsum board.
R702.4.2	Fiber-cement, fiber-mat reinforced cementitious backer units, glass mat gypsum backers and fiber-reinforced gypsum backers	R702.4.2	Backer board	Section reorganized to reference permitted backer board materials in a new table for clarity.
		Table R702.4.2	Backer Board Materials	
Table R702.7.1	Class III Vapor Retarders	Table R702.7.1	Class III Vapor Retarders	Insulated sheathing is replaced with Continuous sheathing for consistency with new definition in Chapter 2 and ASHRAE 90.1. The use of spray foam in accordance with Note a has been revised to deleted the minimum density of 2 lbs/ft ³ and replaced with a maximum permeance of 1.5 perms.

R703.1	General (exterior covering)	R703.1	General (exterior covering)	New exception added for log walls designed and constructed in accordance with ICC 400.
R703.1.2	Wind resistance	R703.1.2	Wind resistance	Section revised to clarify that wall coverings, backing materials, and their attachments have to be designed for wind loads based on wall loads and an effective wind area of 10 square feet.
R703.1.3	Load resistance	R703.1.2.1	Wind resistance of soffits	Section revised to clarify that soffits and their attachments have to be designed for wind loads based on wall loads and an effective wind area of 10 square feet.
R703.2	Water-resistive barrier	R703.2	Water-resistive barrier	Exceptions 2 and 3 have been deleted as they are addressed elsewhere in the code.
Table R703.4	Weather-resistant Siding Attachment and Thickness	Table R703.3(1)	Siding Minimum Attachment and Thickness	Entire table has been reformatted and reorganized. Many of the table notes have been relocated as new sections for clarity.
Table R703.4 Note k	Weather-resistant Siding Attachment and Thickness	R703.5	Wood, hardboard and wood structural panel siding	Revised to require hardboard siding used as architectural trim to comply with CPA/ANSI A 135.7.
R703.3.3	Attachment	-	-	Section deleted. Wood, hardboard and wood structural panel siding required to be installed in accordance with Table R703.3(1).
R703.3.4	Minimum thickness (wood, hardboard and wood structural panel siding)	-	-	Section deleted. Wood, hardboard and wood structural panel siding required to be the minimum thickness specified in accordance with Table R703.3(1).
R703.4	Attachment	R703.3	Nominal thickness and attachments	Section reorganized as part of reorganization of Table R703.3(1). New language clarifies that the attachment requirements Table R703.3(1) are for wood frame construction. New language refers to New Table R703.3(2) for cold-formed steel frame construction.
		R703.3.1	Wind limitations	Wind limitations to using the prescriptive siding attachment table have been located to a new section. References new Table R703.3.1 in addition to a maximum design pressure of 30 psf.

		Table R703.3.1	Limits for Attachment Per Table R703.3.1	New table specifies maximum heights for using the prescriptive siding attachment table based on wind speed and exposure.
		Table R703.3.2	Optional Siding Attachment Schedule for Fasteners Where No Stud Penetration Necessary	New table providing prescriptive attachment for exterior wall coverings to wood structural panel sheathing in lieu of driving fasteners directly into studs.
-	-	Table R703.3(2)	Screw Fastener Substitution for Siding Attachment to Cold-formed Steel Light Frame Construction	New table providing screw substitution sizes for cold-form steel based on the nail sizes specified in Table R703.3(1)
R703.5.1	Application (wood shakes and shingles)	R703.6.1	Application (wood shakes and shingles)	The minimum spacing required for expansion has been changed to 1/8 to 1/4 inch for adjacent shingles and 3/8 to 1/2 inch for adjacent shakes.
R703.5.3	Attachment	R703.6.3	Attachment	Minimum fasteners permitted to be used for wood shake and shingle exterior wall coverings has been strengthened. New tables specify minimum fastener dimensions based on the product type.
		Table R703.6.3(1)	Single Course Sidewall Fasteners	
		Table R703.6.3(2)	Double Course Sidewall Fasteners	
R703.6.4	Application (exterior plaster)	R703.7.4	Application (exterior plaster)	Exception for applications installed in accordance with ASTM C 926 has been revised to include the reference in ASTM C 926 Section 8 to Section X1.4.2 of the Appendix.
R703.6.5	Curing (exterior plaster)	R703.7.5	Curing (exterior plaster)	New exception for applications installed in accordance with ASTM C 926 and includes the reference in ASTM C 926 Section 8 to Section X1.4.2 of the Appendix.
R703.7	Stone and masonry veneer, general	R703.8	Anchored stone and masonry veneer, general	The term "anchored" has been added to the charging language to clarify the distinction between adhered veneers. The wind speed limiting the use of the prescriptive provisions of Section R703.8 has been changed from V_{asd} less than 130 mph to V_{ult} less than 165 mph.
Figure R703.7	Masonry Veneer Wall Details	Figure R703.8	Typical Masonry Veneer Wall Details	New footnote to the figure clarifies that Figure R703.8 provides typical construction details and for actual mandatory requirements to see the indicated sections of text.

R703.7.2.1	Support by steel angle	R703.8.2.1	Support by steel angle	Section revised to permit the steel angle supporting masonry to be anchored to cold-formed steel framing with the connections specified.
R703.7.2.2	Support by roof construction	R703.8.2.2	Support by roof construction	Section revised to permit the steel angle supporting masonry to be anchored to cold-formed steel framing with the connections specified.
R703.9.1	Exterior insulation and finish system (EIFS)	R703.9.1	Exterior insulation and finish system (EIFS)	Section revised to clarify the EIFS systems without drainage are only permitted to be used over concrete or masonry wall assemblies.
R703.9.2	Exterior insulation and finish system (EIFS) with drainage	R703.9.2	Exterior insulation and finish system (EIFS) with drainage	Section revised to clarify the EIFS systems with drainage are required on all wall assemblies except concrete or masonry wall assemblies. The provisions of Section R703.9.2.1, R703.9.2.2, R703.9.3, R703.9.4, R703.9.4.1, and R703.9.4.2 have been merged into Section R703.9.1 and R703.9.2 as applicable.
R703.10.1	Panel siding (fiber cement siding)	R703.10.1	Panel siding (fiber cement siding)	Section revised to permit fiber cement panel siding to comply with ISO 8336, Category A, minimum Class 2.
R703.10.2	Lap siding (fiber cement siding)	R703.10.2	Lap siding (fiber cement siding)	Section revised to permit fiber cement lap siding to comply with ISO 8336, Category A, minimum Class 2.
-	-	R703.11.1.1	Fasteners (vinyl siding)	Fastening requirements for vinyl siding have been clarified and relocated from Notes to Table R703.3(1) to stand-alone sections.
-	-	R703.11.1.2	Penetration depth (vinyl siding)	
-	-	R703.11.1.3	Spacing (vinyl siding)	
R703.11.2	Installation over foam plastic sheathing (vinyl siding)	R703.11.2	Installation over foam plastic sheathing (vinyl siding)	Section revised to include insulated vinyl siding to the scope of this section. Requires vinyl siding to have a wind pressure rating in accordance with new Table R703.11.2 when installed over foam plastic sheathing.
-	-	Table R703.11.2	Adjusted Minimum Design Wind Pressure Requirement for Vinyl Siding	The adjustment factors for the design wind pressure rating for vinyl siding installed over foam plastic sheathing have been deleted and new Table R703.11.2 specifies minimum design wind pressure ratings based on wind speed, exposure, and

				whether interior gypsum wallboard installed or not. The new required design wind pressure ratings are calculated using the previous adjustment factors.
-	-	R703.13	Insulated vinyl siding	New section requiring insulated vinyl siding to comply with ASTM D 7793. New subsection requires insulated vinyl siding and accessories to be installed in accordance with the manufacturer's instructions.
-	-	R703.14	Polypropylene siding	New section requiring polypropylene siding to comply with ASTM D 7254. New subsections address installation, fastener requirements, and fire separation.
-	-	R703.15	Cladding attachment over foam sheathing to wood framing	New section providing prescriptive requirements for attaching cladding over foam sheathing to wood framing. New Tables R703.15.1 and R703.15.2 specify maximum foam thicknesses of foam sheathing for direct attachment to framing and attachment to furring respectively.
-	-	R703.16	Cladding attachment over foam sheathing to cold-formed steel framing	New section providing prescriptive requirements for attaching cladding over foam sheathing to cold-formed steel framing. New Tables R703.15.1 and R703.15.2 specify maximum foam thicknesses of foam sheathing for direct attachment to framing and attachment to furring respectively.
-	-	R703.17	Cladding attachment over foam sheathing to masonry or concrete wall construction.	New section providing prescriptive requirements for attaching cladding over foam sheathing to masonry or concrete wall construction.
Chapter 8: Roof-Ceiling Construction				
R802.1.1	Identification	R802.1.1	Identification	Section revised to clarify the process by which lumber design values are certified and recognized in the code.
R802.1.5	Structural log members	R802.1.3	Structural log members	Section revised to require structural log members to comply with ICC-400.
-	-	R802.1.6	Cross-laminated timber	New section requiring cross-laminated

				timber to manufactured and identified as required by ANSI/APA PRG 320.
-	-	R802.1.7	Engineered wood rim board	New section requiring engineered wood rim boards to conform to ANSI/APA PRR 410 or be evaluated in accordance with ASTM D 7672. Structural capacities are required to be in accordance with ANSI/APA PRR 410 or established in accordance with ASTM D 7672. Rim boards conforming to ANSI/APA PRR 410 are required to be marked in accordance with that standard.
R802.10.2.1	Applicability limits (wood trusses)	R802.10.2.1	Applicability limits (wood trusses)	New language limits truss roof framing constructed in accordance with this section sites subjected to a maximum wind speed of 140 mph for Exposure B or C.
R803.2.3.1	Sheathing fastenings (roof sheathing)	R803.2.3.1	Sheathing fastenings (roof sheathing)	The minimum dimensional requirements for ring shank nails have been deleted and replaced with a reference to RSRS-01 nails in accordance with ASTM F1667.
R806.1	Ventilation required (roof ventilation)	R806.1	Ventilation required (roof ventilation)	Exception permitting attic ventilation to not be required when determined not necessary by the code official due to atmospheric or climatic conditions has been deleted.
R806.5	Unvented attic and unvented enclosed rafter assemblies	R806.5	Unvented attic and unvented enclosed rafter assemblies	Section revised for clarity and to align the provisions with the FBCB.
Table R806.5	Insulation for Condensation Control	Table R806.5	Insulation for Condensation Control	New Note b provides a calculation procedure to determine rigid board or air impermeable insulation R-values for roof assemblies that have different ceiling insulation R-values.
R807.1	Attic access	R807.1	Attic access	Section revised to clarify that the volume of space required for an attic access is to be measured based on the actual usable space.
Chapter 9: Roof Assemblies				
R903.2	Flashing	R903.2	Flashing	New language clarifies that flashing is required to be used to seal roofing systems where the system is interrupted or

				terminated.
R904.4.1	Nails	R904.5.1	Nails	Section revised to include TAS 114 Appendix E for corrosion resistance and delete ASTM A641 reference which is a requirement in ASTM F1667.
R904.4.3	Clips	R904.5.3	Clips	Section revised to require stainless steel clips to conform to ASTM A240/A240M
⋮	⋮	R905.1.1	Underlayment	<p>New section for underlayment. Underlayment requirements for all roof coverings have been consolidated into a single location in Section R905.1.1. Requires underlayment to comply with, be applied, and be attached in accordance with New Table R905.1.1.</p> <p>New exception regarding the use of synthetic underlayments requires them to be an approved alternate to ASTM D 226 Type II and a minimum tear strength of 20 lbs in accordance with ASTM D 1970 or ASTM D 4533. Attachment is required according to the method in Table R905.1.1 for the applicable roof covering and slope. Metal cap nails are required where V_{ult} equals or exceeds 150 mph.</p>
⋮	⋮	Table R905.1.1	Underlayment Table	<p>Required type, installation, and fastening of underlayments for roof coverings have been consolidated into new Table R905.1.1. Underlayment complying with ASTM D 226 Type II or ASTM D 4869 Type IV (ASTM D 6757 for some roof coverings) is now required for all roof coverings where the roof slope is 4:12 and greater</p>
R905.2.4	Asphalt shingles	R905.2.4	Asphalt shingles	ASTM D 225 has been deleted as an option for asphalt shingles
R905.2.5	Fasteners	R905.2.5	Fasteners	New exception permits an alternate method of attachment complying with the wind load requirements of Chapter 16 of the <i>Florida Building Code, Building</i> if the architectural appearance is to be preserved from

				below. The alternative attachment is required to be prepared, signed and sealed by a Florida-registered architect or a Florida-registered engineer, which architect or engineer shall be proficient in structural design.
R905.2.6.1	Wind resistance of asphalt shingles	R905.2.6.1	Classification of asphalt shingles	Section revised to clarify that Shingles classified as ASTM D 3161 Class D or ASTM D 7158 Class G are acceptable for use where “V _{asd} is equal to or less than 100-mph.”
R905.3.3	Underlayment (clay and concrete tile)	R905.3.3	Underlayment (clay and concrete tile)	Section revised to require the required underlayment types to comply with the underlayment manufacturer’s instruction in accordance with the FRSA/TRI Florida High Wind Concrete and Clay Roof Tile Installation Manual, Fifth Edition.
R905.3.7.1	Hip and ridge tiles	R905.3.7.1	Hip and ridge tiles	Section revised to permit hip and ridge tiles to be installed in accordance with RAS 118, 119, or 120.
R905.4	Metal roof shingles	R905.4	Metal roof shingles	New language requires metal roofing shingles to be factory or field manufactured in accordance with the manufacturers’ Product Approval specifications and limitations of use. Additionally, metal roofing shingles are required to be factory or field manufactured under a quality assurance program that is audited by a third- party quality assurance entity approved by the Florida Building Commission for that purpose.
R905.7	Wood shingles	R905.7	Wood shingles	Entire section revised to required wood shingles to be installed in accordance with the Cedar Shake and Shingle Bureau New Roof Construction Manual or RAS 130. Requires the uplift resistance to be equal to or greater than the design uplift pressure listed in Table R301.2(2)
R905.7.6.1	Fasteners	R905.7.6.1	Fasteners	Section revised to require the use of Type 304 (Type 316 for coastal areas) stainless

				steel ring-shank nails for attaching wood shingles.
R905.8	Wood shakes	R905.8	Wood shakes	Entire section revised to required wood shakes to be installed in accordance with the Cedar Shake and Shingle Bureau New Roof Construction Manual or RAS 130. Requires the uplift resistance to be equal to or greater than the design uplift pressure listed in Table R301.2(2)
R905.8.7.1	Fasteners	R905.8.7.1	Fasteners	Section revised to require the use of Type 304 (Type 316 for coastal areas) stainless steel ring-shank nails for attaching wood shakes.
R905.10	Metal roof panels	R905.10	Metal roof panels	New language requires metal roofing panels to be factory or field manufactured in accordance with the manufacturers' Product Approval specifications and limitations of use. Additionally, metal roofing panels are required to be factory or field manufactured under a quality assurance program that is audited by a third- party quality assurance entity approved by the Florida Building Commission for that purpose.
R905.10.4	Attachment	R905.10.4	Attachment	The specific fasteners previously required for metal roof panels are now only required in the absence of manufacturer's installation instructions. For copper roofs, the use of copper (not hard) brass, and bronze fasteners are now permitted.
R905.14	Sprayed polyurethane foam roofing	R905.14	Sprayed polyurethane foam roofing	Section revised to permit sprayed polyurethane foam roofing to be installed in compliance with RAS 109 and 109A.
R905.14.2	Material standards (sprayed polyurethane foam roofing)	R905.14.2	Material standards (sprayed polyurethane foam roofing)	Section revised to permit sprayed polyurethane foam insulation to comply with ASTM D 7425.
-	-	R905.14.3	Protective Coating Material Standards	New table specifies applicable material standards for liquid protective coatings applied following the application of the foam.
R905.16	Building-integrated photovoltaic roofing modules/shingles	R905.16	Building-integrated photovoltaic roofing modules/shingles	Section revised to require building-integrated photovoltaic roofing

				modules/shingles to also comply with Section R324 and NFPA 70.
R907.7.1.2	Roof decking attachment for wood structural panels (wind mitigation)	R908.7.1.2	Roof decking attachment for wood structural panels (wind mitigation)	Revised to require the ring shank supplement ASTM F1667 classification RSRA-01 ring shank nails
-	-	R908.1.1	Repairing, replacing or recovering roof coverings	New section requiring where more than 25 percent of the total roof area or roof section is repaired, replaced, or recovered in a 12-month period, the entire existing roof system or section is required to be replaced to conform to the requirements of this code. This new section adds language from the 2010 FBCR that was inadvertently omitted from the 5 th Edition (2014) FBCR.
Chapter 10: Chimneys and Fireplaces				
R1002.2	Installation (masonry heaters)	R1002.2	Installation (masonry heaters)	Section revised to permit masonry heaters to be in accordance with CEN 15250.
R1002.5	Masonry heater clearance	R1002.5	Masonry heater clearance	Exception 2 revised to permit masonry heaters to be in accordance with CEN 15250.
R1003.18	Chimney clearances	R1003.18	Chimney clearances	Exception 3 has been revised to reduce the minimum clearance of combustible trim or sheathing from 12 inches to 8 inches.
-	-	R1004.5	Gasketed fireplace doors	New section prohibiting gasketed fireplace door from being installed on a factory-built fireplace except where the fireplace system has been specifically tested, listed and labeled for such use in accordance with UL 127
R1006.2	Exterior air intake	R1006.2	Exterior air intake	Section revised to require the exterior air intake to not be located at an elevation higher than the firebox for other than listed factory-built fireplaces.
R1006.5	Outlet	R1006.5	Outlet	Section revised to require the exterior air outlet shall be located in the back or side of the firebox chamber or be located outside of the firebox, at the level of the hearth and not greater than 24 inches (610mm) from the firebox opening.
Chapter 13: General Mechanical System Requirements				

M1305.1	Appliance access for inspection service, repair and replacement	M1305.1	Appliance access for inspection service, repair and replacement	Requirement that room heaters have at least 18 inches of working space has been deleted.
M1305.1.3.1	Electrical requirements	M1305.1.3.1	Electrical requirements	Section revised to require exposed lamps to be protected from damage by location of lamp guards.
M1305.1.4.3	Electrical requirements	M1305.1.4.3	Electrical requirements	Section revised to require exposed lamps to be protected from damage by location of lamp guards.
M1306.2.1	Labeled assemblies (clearance reduction)	M1306.2.1	Labeled assemblies (clearance reduction)	New section permitting reduced clearance using approved reduced clearance protective assemblies listed and labeled in accordance with UL 1618.
M1308.2	Protection against physical damage	M1308.2	Protection against physical damage	Section reorganized into 3 new sections for clarity. New section added addressing protection for piping based on the proximity to the piping to the edge of the face of the framing member to which a membrane will be attached.
		M1308.2.1	Piping through bored holes or notches	
		M1308.2.2	Piping in other locations.	
Chapter 14: Heating and Cooling Equipment and Appliances				
M1401.1	Installation	M1401.1	Installation	Section revised to require air-handling units installed in attics to comply with Section R403.3.6 of the FBCEC.
M1401.3	Sizing	M1401.3	Equipment and appliance sizing	Section revised to permit heating and cooling equipment and appliances to be sized in accordance with approved sizing methodologies other than ACCA Manual S. Two new exceptions permit heating and cooling equipment and appliances to not be limited to the capacities determined in accordance with Manual S where either of the listed criteria is met.
M1403.1	Heat pumps	M1403.1	Heat pumps	The minimum unobstructed total area of the outside and return air ducts or openings to a heat pump has been deleted. UL/CSA/ANCE 60335-2-40 has been added as option for listing and labeling heat pumps.
-	-	M1403.2	Foundations and supports	Section deleted.

M1410.1	General (vented room heaters)	M1410.1	General (vented room heaters)	Section revised to clarify that vented room heaters comply with ASTM E 1509 are for pellet-fuel burning.
M1410.2	Floor mounting	M1410.2	Floor mounting	Exception 1 has been revised to required floor protectors to be listed and labeled in accordance with UL 1618.
M1411.3.2	Drain pipe materials and sizes	M1411.3.2	Drain pipe materials and sizes	Polybutylene has been deleted as a component of the condensate disposal system and PE-RT and polypropylene have been added. Section revised to clarify that the condensate waste and drain line size is required to be not less than ¾ inch nominal diameter.
-	-	M1411.3.3	Drain line maintenance	New section requiring condensate drain lines to be configured to permit the clearing of blockages and performance of maintenance without requiring the line to be cut.
-	-	M1411.4	Condensate pumps	New section requires condensate pumps located in uninhabitable spaces, such as attics and crawl spaces, to be connected to the appliance or equipment served such that when the pump fails, the appliance or equipment will be prevented from operating.
1411.5	Insulation of refrigerant piping	1411.6	Insulation of refrigerant piping	Insulation for piping and fittings for refrigerant vapor lines has been changed to have a thermal resistivity of not less than R-4.
-	-	M1411.7	Location and protection of refrigerant piping	New section requiring refrigerant piping installed within 1 ½ inches of the underside of roof decks to be protected from damage caused by nails and other fasteners.
M1411.6	Locking access port caps	M1411.8	Locking access port caps	New exception for locking-type tamper-resistant caps if ports are located inside the condensing unit cabinet.
M1412.1	Approval of equipment (absorption systems)	M1412.1	Approval of equipment (absorption systems)	Section revised to permit absorption systems to comply with UL/CSA/ANCE 60335-2-40.
M1413.1	General (evaporative cooling equipment)	M1413.1	General (evaporative cooling equipment)	Section revised to permit evaporative cooling equipment and appliances to comply

				with UL/CSA/ANCE 60335-2-40.
Chapter 15: Exhaust Systems				
M1502.4.1	Material and size (clothes dryer exhaust)	M1502.4.1	Material and size (clothes dryer exhaust)	New exception permits exhaust ducts to be 4 inches nominal in diameter Schedule 40 PVC when horizontally run beneath the slab.
-	-	M1502.4.4	Dryer exhaust duct power ventilators	New section requiring domestic dryer exhaust duct power ventilators to be listed and labeled to UL 705.
-	-	M1502.4.5.3	Dryer exhaust duct power ventilator	New section limiting the length of dryer exhaust duct power ventilator in accordance with the manufacturer's installation instructions.
M1502.4.5	Length identification	M1502.4.6	Length identification	Section revised to require identification of the exhaust duct equivalent length where the equivalent length exceeds 35 feet.
M1503.2	Duct material	M1503.2	Duct material	Exceptions for using schedule 40 PVC pipe for ducts for domestic cooking appliances equipped with down-draft exhaust systems has been revised to require the PVC duct to extend not more than 8 inches above grade outside the building.
M1503.4	Makeup air required	M1503.4	Makeup air required	Section revised to clarify that makeup air can be mechanically or naturally provided. Also clarifies that electrically-operated and gravity dampers can be used to limit the amount of conditioned air that leaves the building when the exhaust is not running.
-	-	M1503.4.1	Location (kitchen exhaust makeup air)	New section requiring kitchen exhaust makeup air do be discharged into the same room in which the exhaust system is located or into rooms or <i>duct systems</i> that communicate through one or more permanent openings with the room in which such exhaust system is located. Openings are required to have a net cross-sectional area not less than the required area of the makeup air supply openings.
-	-	M1506.2	Duct length (exhaust ducts and exhaust openings)	New section requiring the length of exhaust and supply ducts used for ventilating equipment to not exceed the maximum

				lengths determined in accordance with new Table M1506.2. New exception to maximum duct length permitted when complying with the manufacturer's design criteria and other method.
-	-	Table M1506.2	Duct Length	New table limiting duct length based on the type of duct, diameter, and fan airflow rating.
Chapter 16: Duct Systems				
Table M1601.1.1 (2)	Gages of Metal Ducts and Plenums Used for Heating and Cooling.	Table M1601.1.1	Duct Construction Minimum Sheet Metal Thickness for Single Dwelling Units	Table has been revised to recognize 30 gauge sheet metal as being appropriate for round ducts 14 inches or less diameter in single dwelling units. Consistent with the 2007 FBCR.
M1601.3	Duct insulation materials.	M1601.3	Duct insulation materials.	Section revised to permit external reflective duct insulation in accordance with ASTM C 1668. Identification requirements also specified.
M1601.4.1	Joints, seams and connections	M1601.4.1	Joints, seams and connections	Section revised to clarify that "closure systems" are tapes and mastic. Also revised to require tapes and mastics used to seal fibrous glass ductwork shall be <i>listed</i> and <i>labeled</i> in accordance with UL 181A and be marked. Requires tapes and mastics used to seal metallic ducts shall comply with UL 181B and be marked. Language requiring round metallic ducts to be mechanically fastened has been deleted. Exception 3 has been revised to state that snap-lock and button-lock do not qualify for the exception to additional closure systems.
-	-	M1601.4.2	Duct lap	New section requiring crimp joints for round and oval metal ducts to be lapped not less than one inch and the male end of the duct to extend into the adjoining duct in the direction of airflow.
M1601.4.3	Support	M1601.4.4	Support	Duct support materials and intervals have been deleted. Factory made ducts listed in accordance with UL181 required to be

				supported in accordance with the manufacturer's installation instructions. Field- and shop-fabricated fibrous glass ducts required to be supported in accordance the SMACNA Fibrous Glass Duct Construction Standards or the NAIMA Fibrous Glass Duct Construction Standards. Field- and shop fabricated metal and flexible ducts required to be supported in accordance with the SMACNA HVAC Duct Construction Standards—Metal and Flexible.
M1602.1	Return air	M1602.1	Outdoor air openings	Sections have been reorganized for clarity and to delete outdated language.
M1602.2	Prohibited sources	M1602.2	Return air openings	
M1602.3	Inlet opening protection			
Chapter 18: Chimneys and Vents				
M1804.4	Door swing	M1804.4	Door swing	New section limiting the location of vent terminals to locations such that doors cannot swing within 12 inches horizontally of the vent terminals. Door stops and closures are not permitted to be used to obtain this clearance.
Chapter 19: Special Appliances, Equipment and Systems				
M1901.3	Prohibited location	-	-	Section prohibiting cooking appliances designed, tested, listed and labeled for use in commercial occupancies to not be installed within dwelling units or within any area where domestic cooking operations occur has been deleted.
Chapter 20: Boilers and Water Heaters.				
M2001.1.1	Standards (boilers)	M2001.1.1	Standards (boilers)	Standards for boilers have been updated.
M2002.5	Boiler low-water cutoff)	M2002.5	Boiler low-water cutoff)	New exception to the low-water cutoff control for coil-type and water-tube-type boilers that require forced circulation of water through the boiler and that are protected with a flow sensing control.
		M2002.6	Operation	Revised to require the low-water cutoff controls and flow sensing controls to automatically stop the combustion operation when water circulation stops.

M2005.1	General (water heaters)	M2005.1	General (water heaters)	Section revised to require water heaters to be installed in accordance with Chapter 28.
Chapter 21: Hydronic Piping				
Table M2101.2	Hydronic Piping Materials	Table M2101.2	Hydronic Piping Materials	Polyethylene (PE) pipe, tubing and fittings (for ground source heat pump loop systems) have been removed from Table M2101.2 and relocated to new Section M2105 and Table M2105.4. Acrylonitrile butadiene styrene (ABS) plastic pipe complying with ASTM D1527, F2806, or F2969 has been added as hydronic piping materials.
Table M2101.9	Hangar Spacing Intervals	Table M2101.9	Hangar Spacing Intervals	PE-RT piping has been added to the table with maximum horizontal and vertical spacings specified. New note a requires the use of a guide for ABS, CPVC, PE-RT and PP pipe for sizes of 2 inches and smaller.
M2101.10	Tests	M2101.10	Tests	Section revised to require that the duration of the test not exceed 20 minutes.
M2103.1	Piping materials (floor heating systems)	M2103.1	Piping materials (floor heating systems)	Copper alloy and PE-RT have been added as piping for embedment in concrete or gypsum materials.
M2103.3	Piping joints	M2103.3	Piping joints	New language specifying soldering criteria for copper and copper alloy piping. PE-RT tubing required to be joined using insert of compression fittings.
M2104.2	Piping joints (low temperature piping)	M2104.2	Piping joints (low temperature piping)	Revised to require PE-RT piping to be installed in accordance with the manufacturer's instructions.
-	-	M2104.3.3	PE-RT insert fittings	New section requiring PE-RT insert fittings to be installed in accordance with the manufacturer's instructions.
-	-	M2105	Ground-Source Heat-Pump System Loop Piping	New section providing criteria for ground-source heat pump loop systems.
Chapter 22: Special Piping and Storage Systems				
M2202.1	Materials (oil piping, fitting and connections)	M2202.1	Materials (oil piping, fitting and connections)	Copper alloy pipe has been added for oil piping, fittings, and connections.
Chapter 23: Solar Thermal Energy Systems				
M2301.2	Installation	M2301.2	Design and installation	Revised to clarify that Section M2301.2 also applies to the design of solar energy systems and that this section and its

				subsections apply specifically to thermal solar energy systems (not photovoltaics).
-	-	M2301.2.2	Collector sensors	New section requiring collector sensor installation, location, and protection of wires from ultraviolet light to be in accordance with SRCC 300.
M2301.2.3	Pressure and temperature relief	M2301.2.3	Pressure and temperature relief valves and system components	Section revised to clarify when temperature and pressure relief valves or pressure relief valves are required and refers to Section P2804 and SRCC 300 for additional requirements. It also requires that system components have a pressure rating that is not less than that of the setting of the pressure relief device.
-	-	M2301.5	Piping insulation	New section requiring piping insulation to be in accordance with the FBCEC. Three exceptions apply.
-	-	M2301.2.7	Storage tank sensors	New section requiring storage tank sensors shall comply with SRCC 300.
M2301.2.6	Expansion tanks	M2301.2.8	Expansion tanks	Section revised to require expansion tanks in solar systems to be installed in solar collector loops that contain pressurized heat transfer fluid. Requires expansion tank systems to be design in accordance with SRCC 300. New exception for expansion tanks in drain-back systems.
-	-	M2301.2.10	Description and warning labels	New section requiring solar thermal systems to comply with the description label and warning label requirements of Section M2301.2.11.2 and SRCC 300.
-	-	M2301.2.11.2	Drain and fill valve labels and caps	New section requiring labels for drain and fill valve caps. Requires drain caps to be installed at drain and fill valves.
M2301.3.1	Collectors	M2301.3.1	Collectors and panels	Revised to require solar thermal collectors and panels to be listed and labeled in accordance with SRCC 100 or SRCC 600.
M2301.4	Prohibited heat transfer fluids	M2301.4	Heat transfer gasses or liquids and heat exchangers	Section revised to prohibit the use of ethylene glycol as a heat transfer fluid. Heat exchangers required to be in accordance with Section P2902.5.2 and SRCC 300.

				Requires heat transfer gases and liquids to be rated to withstand the system's maximum design temperature under operating conditions without degradation.
-	-	M2301.6	Filtering	New section requiring air provided to occupied spaces that passes through thermal mass storage systems by mechanical means to be filtered for particulates at the outlets of the thermal mass storage system.
-	-	M2301.7	Solar thermal systems for heating potable water	New provisions addressing the use of solar thermal systems for heating potable water.
M2302	Photovoltaic Solar Energy Systems	-	-	Section deleted and provisions relocated to Section R324 and other appropriate sections of code as applicable.
Chapter 24: Fuel Gas				
G2403	Definitions: Air, Makeup	G2403	Definitions: Air, Makeup	Definition revised to clarify the origin and composition of makeup air for consistency with ASHRAE 62.1
G2403	Definitions: Appliance	G2403	Definitions: Appliance	Definition revised to include apparatus that compress fuel gases.
-	-	G2404.11	Condensate pumps	New section requiring Condensate pumps installed in uninhabitable spaces, such as attics and crawl spaces, to be connected to the appliance or equipment served such that when the pump fails, the appliance or equipment will be prevented from operating.
-	-	G2409.2	Reduction table	Section revised to require reduced clearance protective assemblies to be listed and labeled in accordance with UL 1618.
G2411.1.1	CSST	G2411.1.1	CSST	Section reorganized for clarity. Permits CSST to be bonded to the lightning protection grounding electrode system.
		G2411.1.1.1	Point of connection	Provision requiring the bonding jumper to connect to a metallic pipe, pipe fitting or CSST fitting has been relocated to a stand-alone section.
		G2411.1.1.2	Size and material of jumper	Provision requiring the bonding jumper to be no smaller than 6 AWG copper wire has been relocated to a stand-alone section.

-	-	G2411.1.1.3	Bonding jumper length	New section limiting the length of the bonding jumper between the connection to a gas piping system and the connection to a grounding electrode system to 75 feet.
-	-	G2411.1.1.4	Bonding connections	New section requiring bonding connections to be in accordance with NFPA 70.
-	-	G2411.1.1.5	Connection devices	New section requiring devices used for making the bonding connection to be listed for the application in accordance with UL 467.
G2412.9	Identification	G2412.9	Identification	Exception to identifying pipe, tubing, and fittings has been revised to include steel pipe section 2 feet and less in length and cut from longer sections of pipe, steel pipe fittings 2 inches and less in size, where identification is provided on the packaging or crating, and where other approved documentation is provided.
-	-	G2412.10	Piping material standards	New section requiring piping, tubing and fittings to be manufactured to the applicable criteria specified in Section G2414 and identified in accordance with Section G2412.9.
G2413.2	Maximum gas demand	G2413.2	Maximum gas demand	Reference to Table G2413.2 for estimating volumetric flow rate of gas when input ratings are not indicated has been deleted. Adjustment for altitude is now only required where the installation is above 2000 feet in elevation.
Table G2413.2	Approximate Gas Input for Typical Appliances	-	-	Table deleted.
G2414.6	Plastic pipe, tubing and fittings	G2414.6	Plastic pipe, tubing and fittings	New language prohibits the use of PVC and CPVC plastic pipe, tubing and fittings for supplying fuel gas.
G2410.10.4	Metallic fittings	G2410.10.4	Metallic fittings	Brass fittings removed from the scope of this section. New criteria added for pipe fittings that are drilled and tapped in the field.
G2415.5	Fittings in concealed locations	G2415.5	Fittings in concealed locations	Section revised to specify the applicable standards for fittings listed for use in concealed locations. The prohibition on right and left couplings has been removed.

G2415.6	Underground penetrations prohibited	G2415.6	Underground penetrations	Section revised to permit underground piping, where installed through the outer foundation or basement wall of a building, provided the piping is encased in a protective sleeve or protected by an approved device or method.
G2415.7	Protection against physical damage	G2415.7	Protection against physical damage	Section reorganized into 4 new sections for clarity. New section added addressing protection for piping based on the proximity to the piping to the edge of the face of the framing member to which a membrane will be attached.
		G2415.7.1	Piping through holes or notches	
		G2415.7.2	Piping installed in other locations	
		G2415.7.3	Shield plates	
-	-	G2415.18	Pipe cleaning	New section prohibiting the use of a flammable or combustible gas to clean or remove debris from a piping system.
G2417.5.1	Leak detection methods	G2417.5.1	Leak detection methods	Language prohibiting the use of matches, candles, open flames or other methods that could provide a source of ignition has been deleted.
G2421.2	MP regulators	G2421.2	MP regulators	Section revised to require additional criteria for MP regulators. Where MP regulators are connected to rigid piping, a union is required to be installed within 1 foot of either side of the MP regulator.
G2422.1	Connecting appliances	G2422.1	Connecting appliances	Section revised to Add a requirement that a Z21.54 listed connector be used to connect portable outdoor appliances to the house piping system.
G2411.1.5	Movable appliances	G2411.1.5	Movable appliances	Section revised to address movable appliances that are not commercial cooking appliances that would be subject to periodic moving.
-	-	G2426.7.1	Door swing	New section prohibiting appliance and equipment vent terminals from being located such that doors swing within 12 inches (305 mm) horizontally of the vent terminal. Door stops or closures are not permitted to be used to obtain this clearance.
G2427.4.1	Plastic piping	G2427.4.1	Plastic piping	Section revised to require appliances that use plastic piping for venting to be listed for

				use with such venting material and for the installation instructions to identify the specific plastic piping material.
G2427.6.9.3	Category II, III, and IV appliances	G2427.6.9.3	Category II, III, and IV appliances	New language added requiring that the sizing of plastic pipe that is specified by the appliance manufacturer as a venting material for Category II, III, and IV appliances to be in accordance with the manufacturer's instructions.
G2427.8	Venting system termination location	G2427.8	Venting system termination location	New clearance provisions have been added for category IV appliance side wall vent terminations to adjacent building openings.
-	-	G2439.4	Dryer exhaust duct power ventilators	New section requiring domestic dryer exhaust duct power ventilators to be listed and labeled to UL 705 for use in dryer exhaust duct systems.
G2439.5.2	Duct installation	G2439.7.2	Duct installation	Section revised to permit ducts to be joined with screws or similar fasteners provided they do not protrude more than 1/8 inch into the inside of the duct.
-	-	G2439.7.4.3	Dryer exhaust duct power ventilator length	New section permitting the maximum length of the exhaust duct to be determined by the dryer exhaust duct power ventilator manufacturer's installation instructions.
G2439.5.6	Length identification	G2439.7.5	Length identification	Section revised to require identification of the exhaust duct equivalent length where the equivalent length exceeds 35 feet.
G2447.2	Prohibited locations (cooking appliances)	G2447.2	Prohibited locations (cooking appliances)	New exception added for appliances that are also listed as domestic cooking appliances.
Chapter 25: Plumbing Administration				
P2502.1	Existing building sewers and drains	P2502.1	Existing building sewers and drains	Section revised to be more specific about the acceptability of existing sewers and drains. Requires an examination to verify the piping is sloped in the correct direction, is not broken, is not obstructed, and is sized for the new drainage load of the new system to be installed.
P2503.4	Building sewer testing	P2503.4	Building sewer testing	Section revised to change the required water test from a 10 foot head of water to a

				5 foot head of water.
P2503.5.1	Rough plumbing	P2503.5.1	Rough plumbing	Section revised to change the required water test for DWV systems from a 10 foot head of water to a 5 foot head of water.
Chapter 26: General Plumbing Requirements				
P2601.2	Connections to drainage system	P2601.2	Connections to drainage system	Section revised to clarify that all connections be direct connections except where the code requires an indirect connection.
P2603.2.1	Protection against physical damage	P2603.2.1	Protection against physical damage	For pipes installed through holes or notches in studs, joists or rafters, the minimum distance from the nearest edge that doesn't require a shield plate has been reduced from 1½ inches to 1¼ inches.
P2603.3	Protection against corrosion	P2603.3	Protection against corrosion	Section rewritten for clarity. Clarifies that Where sheathing protects piping that penetrates concrete or masonry walls or floors, the sheathing is required to be installed in a manner that allows movement of the piping within the sheathing.
P2604.4	Protection of footings	P2604.4	Protection of footings	Section revised to more specifically define the bearing plane.
Figure P2604.4	Pipe Location with Respect to Footings	-	-	Figure deleted.
Table P2605.1	Piping Support	Table P2605.1	Piping Support	PEX and PE-RT piping with diameters 1¼ and larger have been added to the table with maximum horizontal and vertical spacings. Brass piping material has been deleted as it is covered under copper alloys. Note b has been revised to specifically define what a mid-story guide is.
P2607.1	General (waterproofing of openings)	P2607.1	Pipes penetrating roofs	Existing section has been separated into two sections for clarity. The phrase "watertight" has been deleted and replace with specific requirements for flashings and waterproof sealants.
		P2607.2	Pipes penetrating exterior walls	
P2609.1	Identification (materials evaluation and listing)	P2609.1	Identification (materials evaluation and listing)	New language permits nipples created from the cutting and threading of approved pipe to not be identified. New section permits identification to be printed on the item packaging or other documentation where

				pipe fittings and pipe nipples are too small to be marked with the manufacturer identification.
P2609.4	Third-party certification	P2609.4	Third-party certification	Revised to clarify that only plumbing products and materials required by the code to be in compliance with a referenced standard are required to be listed by a third-party certification agency.
Chapter 27: Plumbing Fixtures				
P2701.1	Quality of fixtures	P2701.1	Quality of fixtures	Section revised for clarity and to provide a direct reference to Table P2701.1
Table P2701.1	Plumbing Fixtures, Faucets and Fixture Fittings	Table P2701.1	Plumbing Fixtures, Faucets and Fixture Fittings	Standard for plastic fixtures, ANSI Z24 has been revised to reflect Z24.1 and Z24.2 have been combined into a single standard.
P2702.1	Plumbing fixtures	P2702.1	Plumbing fixtures	Exception has been revised to permit the strainer to be omitted on hub drains that receive clear water waste.
P2706.1	General (wasted receptors)	P2706.1	General (wasted receptors)	Section revised to permit the strainer to be omitted on hub drains that receive clear water waste. Redundant language has been deleted. Exception 1 has been relocated as stand-alone Section P2706.1.1 for clarity.
		P2706.1.1	Hub drains	
-	-	P2708.2	Shower drain	New section requiring shower drains to have an outlet size of not less than 1½ inches in diameter.
P2709.2	Lining required (shower receptors)	P2709.2	Lining required (shower receptors)	A new exception has been added to the lining requirement: 3. Shower compartments where the finished shower drain is depressed a minimum of 2 inches (51 mm) below the surrounding finished floor on the first floor level and the shower recess is poured integrally with the adjoining floor.
P2710.1	Shower walls	P2710.1	Shower walls	Revised to clarify that this section also applies to walls above bathtubs that have a wall-mounted shower head.
P2712.1	Approval (water closets)	P2712.1	Approval (water closets)	New language requires water closets equipped with a dual flushing tank to comply

				with ASME A112.19.14.
P2716.2	Water supply required	P2716.2	Water supply required	Unenforceable language regarding adequate supply of water at a sufficient flow rate has been deleted.
P2717.1	Protection of water supply (dishwashing machines)	P2717.1	Protection of water supply (dishwashing machines)	Section revised to provide references for compliance for the required air gap or backflow preventer. The air gap is required to comply with ASME A112.1.3 or A112.1.2. The backflow preventer is required to comply with Section P2902.
P2717.2	Sink and dishwasher	P2717.2	Sink and dishwasher	Sections combined into a single section for clarity. Requires the combined discharge from a dishwasher and sink to be served by a trap of not less than 1½ inches in outside diameter.
P2717.3	Sink, dishwasher, and food grinder			
-	-	P2725	Nonliquid Saturated Treatment Systems	New section requiring nonliquid saturated treatment systems to comply with NSF 41.
Chapter 28: Water Heaters				
P2801.1	Required	P2801.1	Required	Section revised to more generally state that hot water is required to be supplied to plumbing fixtures and appliances intended for bathing, washing, or culinary purposes.
-	-	P2801.2	Drain valves	New section requiring drain valves for emptying to be installed at the bottom of each tank-type water heater and hot water storage tank. The drain valve inlet is required to be not less than ¾ inch nominal iron pipe size and the outlet provided with a male garden hose thread.
P2801.5	Required pan	P2801.6	Required pan	Language requiring listed pans to comply with CSA LC3 has been deleted. Aluminum not less than 0.0236 inch thick and plastic not less than 0.036 inch thick have been added as materials for the required pan. Prohibits the use of plastic pans beneath gas-fired water heaters.
P2801.5.1	Pan size and drain	P2801.6.1	Pan size and drain	New language permits the pan drain to not be installed for a replacement water heater installation where a pan drain was not previously installed.

-	-	P2802	Solar Water Heating Systems	New section addressing mixing valves and isolation valves in solar thermal systems.
P2803.6.1	Requirements for discharge pipe	P2804.6.1	Requirements for discharge pipe	Item 10 has been revised to specify a minimum discharge piping termination of not less than two times the discharge pipe diameter above the flood level rim of the waste receptor. New Item 14 requires relief valve discharge piping construction PEX or PE-RT to be one nominal size larger than the size of the relief valve outlet.
Chapter 29: Water Supply and Distribution				
-	-	P2901.2	Identification of nonpotable water systems	New section addressing identification of nonpotable water systems for safety reasons.
		P2901.2.1	Signage required	
		P2901.2.2	Distribution pipe labeling and marking	
		P2901.2.2.1	Color	
		P2901.2.2.2	Lettering size	
P2901.2.2.3	Identification tape			
P2902.1	General (protection of potable water supply)	P2902.1	General (protection of potable water supply)	A specific reference to backflow prevention assemblies and backflow prevention devices for protection of the potable water supply.
Table P2902.3	Application of backflow preventers	Table P2902.3	Application of backflow preventers	Table reorganized to better identify the different backflow protection methods: backflow prevention assemblies, backflow prevention devices and other means or methods.
P2902.3.2	Atmospheric-type vacuum breakers	P2902.3.2	Atmospheric-type vacuum breakers	New language requires both types of vacuum breakers to be installed with the outlet continuously open to the atmosphere. Requires the critical level of the atmospheric-type vacuum breaker to be set at not less than 6 inches (152 mm) above the highest elevation of downstream piping and the flood level rim of the fixture or device.
P2902.3.3	Backflow preventer with intermediate atmospheric vent	P2902.3.3	Backflow preventer with intermediate atmospheric vent	New language prohibits the use of backflow preventer with intermediate atmospheric vent as a means of protection where any hazardous chemical additives are introduced downstream of the device.

P2902.3.4	Pressure vacuum breaker assemblies	P2902.3.4	Pressure vacuum breaker assemblies	New language requires the critical level of a pressure vacuum breaker and a spill resistant vacuum breaker assembly to be set at not less than 12 inches above the highest elevation of downstream piping and the flood level rim of the fixture or device.
P2902.3.6	Double check-valve assemblies	P2902.3.6	Double check backflow prevention assembly	Section revised for clarity.
P2902.5.5	Solar systems	P2902.5.5	Solar thermal systems	Section revised to clarify that it applies to solar thermal systems. New sections have been added to clarify requirements for direct and indirect systems connected to potable or other than potable water distribution systems.
		P2902.5.5.1	Indirect systems	
		P2902.5.5.2	Direct systems for potable water distribution systems	
		P2902.5.5.3	Direct systems for other than potable water distribution systems.	
Table P2903.1	Required Capacities at Point of Outlet Discharge	Table P2903.1	Required Capacities at Point of Outlet Discharge	Minimum flow rates for lavatories, showers, and residential sinks have been reduced. New not a permits the use the manufacturer flow rate for shower mixing valves where it is lower than the minimum required by Table 403.1.
P2903.3	Minimum pressure	P2903.3	Minimum pressure	The minimum static pressure of 40 psf at the building entrance has been deleted. New language requires the use of an elevated water tank, a hydropneumatic pressure booster system or a water pressure booster pump where the water pressure supplied by the public water main or individual water supply system is insufficient to provide for the minimum pressures and quantities for the plumbing pressures in the building.
P2903.8	Gridded and parallel water distribution systems	P2903.8	Gridded and parallel water distribution systems	Section revised to clarify that gridded systems are not permitted for hot water distribution systems.
P2903.8.3	Orientation	-	-	Section deleted.
P2903.4	Valve requirements	P2903.4	Valve requirements	Section revised to require all valves intended to supply drinking water to comply with NSF 61 not just ball valves, gate valves, butterfly valves, globe valves and plug. Requires valves to comply with new Table P2903.4.

-	-	Table P2903.4	Valves	New table has been added to identify appropriate performance standards for valves.
-	-	P2903.11	Drain water heat recovery unit	New section requiring drain water heat recovery units to be in accordance with Section R403.5.4 of the FBCEC.
P2904.3	Sprinkler piping support	P2904.3	Sprinkler piping support	New exception permits the support of plastic piping to be in accordance with the manufacturer's installation instructions.
-	-	P2905	Heated Water Distribution Systems	New section requiring circulation systems and heat trace systems installed to bring heated water in close proximity to fixtures to comply with Section R403.5.17 of the FBCEC. Demand recirculation systems are required to comply with Section R403.5.2 of the FBCEC.
Table P2905.4	Water Service Pipe	Table P2905.4	Water Service Pipe	Chlorinated polyvinyl chloride/aluminum/chlorinated polyvinyl chloride (CPVC/AL/CPVC) has been added as piping material and is required to comply with ASTM F2855. Asbestos-cement piping has been deleted.
P2905.4.1	Dual check-valve-type backflow preventer	P2902.4	Dual check backflow preventer	Terms clarified for consistency with ASSE 1024. Section relocated to section addressing other backflow preventers since the FBCR does not require a backflow preventer on the water supply system.
P2905.4.2	Water service installation	P2906.4.1	Separation of water service and building sewer	Section revised and reorganized for clarity and consistency with the FBCP.
Table P2905.5	Water Distribution Pipe	Table P2906.5	Water Distribution Pipe	Chlorinated polyvinyl chloride/aluminum/chlorinated polyvinyl chloride (CPVC/AL/CPVC) has been added as piping material and is required to comply with ASTM F2855.
Table P2905.6	Pipe Fittings	Table P2906.6	Pipe Fittings	New standards for various types of pipe fittings have been added and inappropriate standards have been deleted.
P2905.9.1.2	CPVC plastic pipe	P2905.9.1.2	CPVC plastic pipe	Section reorganized for clarity.
-	-	P2906.9.1.3	CPVC/AL/CPVC pipe	New section addressing joints in CPVC/AL/CPVC pipe.

P2905.18	Press joints	P2906.18	Press-connect joints	Section revised to provide more specification for press-connect joints.
P2905.19.1	Flared joints (PE-RT)	-	-	Section deleted because PE-RT pipe cannot be flared.
-	-	P2910	Nonpotable Water Systems	New section addressing the collection, storage, treatment and distribution of nonpotable water systems. Provisions are based on the International Green Construction Code.
-	-	P2911	On-site Nonpotable Water Reuse Systems	New section addressing the construction, installation, alteration and repair of on-site nonpotable water reuse systems. Provisions are based on the International Green Construction Code.
-	-	P2912	Nonpotable Rainwater Collection and Distribution Systems	New section addressing the construction, installation, alteration and repair of rainwater collection and conveyance systems. Provisions are based on the International Green Construction Code
-	-	P2913	Reclaimed Water Systems	New section addressing the construction, installation, alteration and repair of systems supplying nonpotable reclaimed water. Provisions are based on the International Green Construction Code
Chapter 30: Sanitary Drainage				
Table P3002.1(1)	Above-ground Drainage and Vent Pipe	Table P3002.1(1)	Above-ground Drainage and Vent Pipe	Brass pipe has been deleted from the table since it is covered under copper-alloys. ASTM B43 has been added as an additional standard for copper and copper-alloy pipe.
Table P3002.1(2)	Underground Building Drainage and Vent Pipe	Table P3002.1(2)	Underground Building Drainage and Vent Pipe	Asbestos-cement piping complying with ASTM C428 has been deleted.
Table P3002.2	Building Sewer Pipe	Table P3002.2	Building Sewer Pipe	Asbestos-cement piping complying with ASTM C428 has been deleted.
Table P3002.3	Pipe Fittings	Table P3002.3	Pipe Fittings	Asbestos-cement piping complying with ASTM C428 has been deleted.
-	-	P3002.2.1	Building sewer pipe near the water service	New section provides a pointer to Section P2905.4.1 regarding the proximity of a building sewer to a water service.
P3003.4	Asbestos cement (joints)	-	-	Section deleted.
P3003.5	Brass	-	-	Section deleted.

P3003.5.1	Brazed joints	-	-	Section deleted.
P3003.5.2	Mechanical joints	-	-	Section deleted.
P3003.5.3	Threaded joints	-	-	Section deleted.
P3003.6.3	Mechanical joint coupling (cast iron)	P3003.4.3	Mechanical joint coupling (cast iron)	Revised to require mechanical joint couplings for hubless pipe and fittings are required to consist of an elastomeric sealing sleeve and a metallic shield that comply with CISPI 310, or ASTM C1277 or ASTM C1540.
P3003.8	Coextruded composite ABS pipe	-	-	Section deleted.
P3003.8.1	Mechanical joints	-	-	Section deleted.
P3003.8.2	Solvent cementing	-	-	Section deleted.
P3003.9	Coextruded composite PVC pipe	-	-	Section deleted.
P3003.9.1	Mechanical joints	-	-	Section deleted.
P3003.9.2	Solvent cementing	-	-	Section deleted.
P3003.10	Copper pipe	P3003.6	Copper and copper-alloy pipe and tubing	Section revised to include copper-alloy materials within the scope of this section.
P3003.10.1	Brazed joints	P3003.6.1	Brazed joints	Section revised to require brazing materials to have a melting point in excess of 1000°F.
P3003.10.3	Soldered joints	P3003.6.3	Soldered joints	Section revised to include copper-alloy materials within the scope of this section.
P3003.11	Copper tubing	-	-	Section deleted.
P3003.11.1	Brazed joints	-	-	Section deleted.
P3003.11.2	Mechanical joints	-	-	Section deleted.
P3003.11.3	Soldered joints	-	-	Section deleted.
P3003.14.2	Solvent cementing (PVC plastic)	P3003.9.2	Solvent cementing (PVC plastic)	New exception added specifying conditions where a primer is not required.
P3003.18.1	Copper or copper-alloy tubing to cast-iron	P3003.13.1	Copper or copper-alloy tubing to cast-iron	The term brass has been changed to copper alloy.
P3003.18.2	Copper or copper-alloy tubing to galvanized steel pipe	P3003.13.2	Copper or copper-alloy tubing to galvanized steel pipe	The term brass has been changed to copper alloy.
P3003.18.3	Cast-iron pipe to galvanized steel or brass pipe	P3003.13.3	Cast-iron pipe to galvanized steel or brass pipe	The term brass has been changed to copper alloy.
P3005.1.5	Dead ends	-	-	Section deleted.
P3005.2 through P3005.2.11	Cleanouts	P3005.2 through P3005.2.11	Cleanouts	Sections have been reorganized for clarity and more logical format.
P3007.3.2	Sump pit	P3007.3.2	Sump pit	Section revised to require the gas-tight removable cover to be installed above grade

				level or floor level, or not more than 2 inches (51 mm) below grade or floor level.
P3007.5	Macerating toilet systems	P3007.5	Macerating toilet systems and pumped waste systems	Section revised to include pump waste systems within the scope of this section.
P3008.1	Sewage backflow	P3008.1	Sewage backflow	New exception for existing buildings permitting fixtures above the elevation of the manhole cover of the next upstream manhole in the public sewer to discharge through a backwater valve.
P3009	Gray Water Recycling Systems	P3009	Subsurface Landscape Irrigation Systems	Section revised based on provisions in the International Green Construction Code.
-	-	P3010	Replacement of Underground Sewers by Pipe-Bursting Methods	New section providing criteria for replacement of underground sewers by pipe-bursting methods.
Chapter 31: Vents				
P3101.2	Trap seal protection	P3101.2	Trap seal protection	Section revised for clarity.
P3103.1	Roof extension	P3103.1	Roof extension	Section revised to require where a roof is used for assembly or as a promenade, observation deck, sunbathing deck or similar purposes, open vent pipes are required to terminate not less than 7 feet above the roof.
P3111.2.2	Connection (combination waste and vent system)	P3111.2.2	Connection (combination waste and vent system)	Section revised to clarify what type of a vent must connect to a combination waste and vent system. Also revised to address situations where only stacks connected to a building drain that had a combination waste and vent system connected to it.
P3114.5	Access and ventilation	P3114.5	Access and ventilation	Section revised to remove the requirement that air admittance valves be installed a ventilated space and now simply requires them to be installed in a location that allows air to enter the valve.
P3114.8	Prohibited installations	P3114.8	Prohibited installations	Section revised to allow the use of an AAV in sump and tank vent systems that are designed by an engineer.
Chapter 32: Traps				
P3002.1	Design of traps	P3002.1	Design of traps	The term brass has been changed to copper and copper-alloy
P3201.2	Trap seals and trap seal	P3201.2	Trap seals	Section revised to identify all the methods

	protections	P3201.2.1	Trap seal protection	available for protecting the trap seal of emergency floor drain traps or traps subject to evaporation. The four methods available are: water supplied trap seal primers, waste supplied trap primer devices, trap seal protection devices, and reclaimed water.
		P3201.2.1.1	Potable water-supplied trap seal primer	
		P3201.2.1.2	Reclaimed or gray-water-supplied trap seal primer valve	
		P3201.2.1.3	Waste-water-supplied trap primer device	
		P3201.2.1.4	Barrier-type trap seal protection device	
P3201.4	Building traps	P3201.4	Building traps	Exemption permitting the use of building traps in special cases where sewer gases are extremely corrosive or noxious, as directed by the building official has been deleted. Section now simply prohibits building traps.
P3201.7	Size of fixture traps	P3201.7	Size of fixture traps	Section revised to require the trap size to be the same nominal size as the fixture tailpiece where the tailpiece of a plumbing fixture is larger than that indicated in Table P3201.7.
Table P3201.7	Size of Traps for Plumbing Fixtures	Table P3201.7	Size of Traps for Plumbing Fixtures	Water closets and note a have been removed from the table since water closets contain an integral trap. Size of traps indicated in the table have been changed from minimum sizes to required sizes.
Chapter 33: Storm Drainage				
Table P3302.1	Subsoil drain pipe	Table P3302.1	Subsoil drain pipe	Asbestos-cement pipe complying with ASTM C 508 has been deleted from the table. SDR 35 PVC pipe complying with ASTM D 3034 has been added to the table.
Chapter 45: Private Swimming Pools				
R4501.6.1	Conformance standard	R4501.6.1	Conformance standard	Standards updated to ANSI/APSP/ICC 3 and ANSI/APSP/ICC 7.
R4501.16	Electrical	R4501.16	Electrical	Section revised to require outlets supplying pool pump motors connected to single-phase 120-volt through 240-volt branch circuits, whether by receptacle or by direct connection, and outlets supplying other electrical equipment and underwater

				luminaires operating at voltages greater than the Low Voltage Contact Limit, connected to single-phase, 120 volt through 240 volt branch circuits, rated 15 or 20 amperes, whether by receptacle or by direct connection, to be provided with ground-fault circuit interrupter protection for personnel.
--	--	--	--	--